

§ 111.105-43

111.15 and IEEE 45-1998 (incorporated by reference; see 46 CFR 110.10-1).

[USCG-2003-16630, 73 FR 65201, Oct. 31, 2008]

§ 111.105-43 Paint stowage or mixing spaces.

A space for the stowage or mixing of paint must not have any electric equipment, except:

- (a) Intrinsically safe electric equipment approved for a Class I, Division 1, Group D (Zone 0 or Zone 1) location;
- (b) Explosionproof electric equipment approved for a Class I, Division 1, Group D (Zone 0 or Zone 1) location; or
- (c) Through runs of marine shipboard cable.

[CGD 74-125A, 47 FR 15236, Apr. 8, 1982, as amended by CGD 94-108, 61 FR 28285, June 4, 1996; 62 FR 23909, May 1, 1997]

§ 111.105-45 Vessels carrying agricultural products.

(a) The following areas are Class II, Division 1, (Zone 10 or Z) locations on vessels carrying bulk agricultural products that may produce dust explosion hazards:

- (1) The interior of each cargo hold or bin.
- (2) Areas where cargo is transferred, dropped, or dumped and locations within 1 meter (3 feet) of the outer edge of these areas in all directions.

(b) The following areas are Class II, Division 2, (Zone 11 or Y) locations on vessels carrying bulk agricultural products that may produce dust explosion hazards:

- (1) All areas within 2 meters (6.5 feet) of a Division 1 (Zone 10 or Z) location in all directions except when there is an intervening barrier, such as a bulkhead or deck.

NOTE TO §111.105-45: Information on the dust explosion hazards associated with the carriage of agricultural products is contained in Coast Guard Navigation and Vessel Inspection Circular 9-84 (NVIC 9-84) "Electrical Installations in Agricultural Dust Locations."

[CGD 94-108, 61 FR 28285, June 4, 1996]

46 CFR Ch. I (10-1-13 Edition)

Subpart 111.107—Industrial Systems

§ 111.107-1 Industrial systems.

(a) For the purpose of this subpart, an industrial system is a system that—

- (1) Is not a ship's service load, as defined in §111.10-1;
 - (2) Is used only for the industrial function of the vessel;
 - (3) Is not connected to the emergency power source; and
 - (4) Does not have specific requirements addressed elsewhere in this subchapter.
- (b) An industrial system that meets the applicable requirements of NFPA NEC 2002 (incorporated by reference, see 46 CFR 110.10-1) must meet only the following:

- (1) The switchgear standards in part 110, subpart 110.10, of this chapter.
 - (2) Part 110, subpart 110.25, of this chapter—Plan Submittal.
 - (3) Subpart 111.01 of this part—General.
 - (4) Subpart 111.05 of this part—Equipment Ground, Ground Detection, and Grounded Systems.
 - (5) Sections 111.12-1(b) and 111.12-1(c)—Prime movers.
 - (6) Subpart 111.105 of this part—Hazardous Locations.
- (c) Cables that penetrate a watertight or fire boundary deck or bulkhead must—
- (1) Be installed in accordance with 46 CFR 111.60-5 and meet the flammability-test requirements of either IEEE 1202 or Category A of IEC 60332-3-22 (both incorporated by reference; see 46 CFR 110.10-1); or
 - (2) Be specialty cable installed in accordance with §111.60-2.

[CGD 94-108, 61 FR 28286, June 4, 1996, as amended at 62 FR 23910, May 1, 1997; USCG-2003-16630, 73 FR 65201, Oct. 31, 2008]

PART 112—EMERGENCY LIGHTING AND POWER SYSTEMS

Subpart 112.01—Definitions of Emergency Lighting and Power Systems

Sec.

112.01-1 Purpose.

112.01-5 Manual emergency lighting and power system.